

SENSOR INSTRUCTIONS







nedlandsgroup.com.au

sales@nedlandsgroup.com.au



HB-S



The ANT-5-4 is a motion sensor that dims lighting from high to low based on movement. This slim, low-profile sensor is designed for installation inside the bottom of a light fixture body.

The sensors use microwave sensing technology that reacts to changes in movement within the coverage area. Once the sensor stops detecting movement and the time delay elapses lights will go from high to low mode and eventually to an OFF position if it is desired. Sensors must directly "see" motion of a person or moving object to detect them, so careful consideration must be given to sensor luminaire placement and lens selection. Avoid placing the sensor where obstructions may block the sensor's line of sight.

Specifications		
Power supply	12V-24V DC, >50mA	
Dim control output	0-10V, max. 25mA sinking current	
HF System	5.8GHz±75MHz	
Transmission power	<0.2mW	
Detection radius	20%/50%/75%/100%(1-8m)	
Mounting height	Max 40ft.(12meters)	
Time setting	10s/1min/5min/10min/15min/20min/30min/60min	
Light-control	24H/10LUX/30LUX/50LUX	
Temperature	-4°F ~ +140°F (-20°C ~ +60°C)	
IP rating	IP65	

A WARNING

- NOTE: Warm up time is 15seconds. After the sensor connects input power first time, the light will keep on 15seconds, then go to dimming to work normally.
- NOTE: Factory Default Setting: 100% sensitivity, Hold on time: 5min, Daylight sensor is 🔅 , Dimming level: 30%.Dimming time: 60minitues.
- NOTE: Any setting changed by remote control, the led light that sensor connect will on/off as confirm.

Corridor Function

This function inside the motion sensor to achieve tri-level control, for some areas which require a light change notice before switch-off. The sensor offers 3 levels of light: 100%-->dimmed light (natural light is insufficient) -->off; and 2 periods of selectable waiting time: motion hold-time and stand-by period; Selectable daylight threshold and freedom of detection area.







Light switches off automatically elapses

Daylight Sensor Function

Open the daylight sensor by push (II) when remote control is in setting condition.



level after the hold-time.



The light remains in dimming

- Hold-time: 30min Setpoint on:50lux
 - Setpoint off:300lux Stand-by Dim: 10% Stand-by period: +∞

Off

(when the smart photocell sensor open, the stand-by time is only +...)

Settings on this demonstration:

The light switches on at 100% when there is movement detected





level at night.

When the natural light The light automatically turns on at 10% when natural light level exceeds setpoint is insuffcient (no motion). off to light, the light will turn off even if when the space is occupied.



Daylight Sensor Function Wiring Diagrams Black: 12-24Vdc Gray: DIM -Purple: DIM + Cable specifications: AWM 2464 /22AWG Driver /80°C /300V -∎ į́, Ш 7 -<u>л 7</u> Шź

FCC STATEMENT

1. This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions:

(1) This device may not cause harmful interference.

(2) This device must accept any interference received, including interference that may cause undesired operation.

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Caution: The user is cautioned that changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

Note: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a

particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

-Reorient or relocate the receiving antenna

-Increase the separation between the equipment and receiver.

-Connect the equipment into an outlet on a circuit different from that to which the receiver is connected

light does not switch on when the sensor switches on the light presence is detected automatically when presence is detected



stand-by level if the surrounding after the stand-by period